

Ročný protokol emisných hodnôt pre RP za : 2011

Palivo		Bez TAP				Spolustaľovanie TAP				
ZL	SPH - 30 min	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
EL	[mg/Nm ³]	-	1300	400	50	-	800	50	30	30
I	[%EL]	10	20	20	30	10	20	20	30	30
N SPH > 2 EL+I		-	1	0	8	-	-	-	-	-
N PDH > EL+I		-	2	0	0	-	191	8	24	0
mesiace s % < 95% (%SPH < 1.2EL+I)			X,		VII,	-	-	-	-	-
N F PDH		3	3	3	1	4	4	4	2	3
% (F) z N _{stabil} (≤5%)		1.6	1.6	1.6	0.8	0.9	0.9	0.9	0.7	0.7
c - priem. hm. koncent. ZL ≤ EL [mg/m _{ns} ³]		22.7	609.3	4.9	11.3	24.2	407.0	5.2	7.3	3.1
množstvo ZL ≤ EL [kg]		4,437.0	112,282.3	959.5	1,929.0	34,808.6	47,481.9	7,142.8	9,360.6	4,532.3
Q Spalin ≤ EL [tis. m ³]		195,213	184,285	195,213	170,945	1,438,903	116,664	1,369,887	1,276,986	1,438,903
c - priem. hm. koncent. ZL > EL [mg/m _{ns} ³]		0.0	730.4	0.0	28.4	-	525.2	41.0	28.7	0.0
množstvo ZL > EL [kg]		0.0	7,981.4	0.0	689.3	-	694,378.1	2,831.4	4,652.3	0.0
Q Spalin > EL [tis. m ³]		0	10,928	0	24,268	-	1,322,240	69,016	161,918	0

Počet hodín za rok: 5132.5						Priemerné mesačné emisné hodnoty [mg/Nm ³]				Priemerné mesačné emisné hodnoty [mg/Nm ³]				
Stav:	Bez	Ust	Náb	ZmQ	Odst	Meranie bez TAP				Meranie so spolustaľovaním TAP				
Deň	-	""	N	Q	Z	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
Jan-11	1488.	0/0	0.	0.	0.									
Feb-11	1344.	0/0	0.	0.	0.									
Mar-11	706.	55/694	0.	0.	0.	39.4	1,069.4	42.0	5.3	38.3	942.3	55.6	6.5	6.9
Apr-11	407.	71/955	0.	0.	0.	42.0	1,072.5	15.5	5.3	40.3	1,011.4	16.2	8.0	4.9
May-11	367.	22/1 095	0.	0.	0.	59.0	999.6	11.6	8.6	57.0	1,016.6	12.6	7.8	6.9
Jun-11	50.	289/1 092	0.	0.	0.	56.1	972.6	7.5	25.2	58.8	1,005.6	8.7	23.6	6.5
Jul-11	425.	149/903	0.	0.	0.	60.3	1,025.3	11.1	32.1	52.5	968.7	10.3	50.2	6.8
Aug-11	386.	292/798	0.	0.	0.	37.8	1,000.4	4.5	18.9	40.0	896.6	4.5	23.0	6.6
Sep-11	4.	257/1 173	0.	0.	0.	50.4	1,002.0	4.5	22.2	45.2	1,001.5	6.7	24.3	6.5
Oct-11	495.	69/919	0.	0.	0.	40.3	928.2	12.4	12.9	41.1	1,000.9	14.6	10.5	5.4
Nov-11	686.	29/718	0.	0.	0.	27.8	859.8	2.0	8.1	34.7	849.0	4.7	14.3	4.1
Dec-11	794.	48/637	0.	0.	0.	47.6	891.9	2.8	12.4	31.8	913.5	3.1	12.6	4.0
SUMA	7152.	281/8 98	0.	0.	0.	46.1	982.2	11.4	15.1	44.0	960.6	13.7	18.1	5.9

Meranie bez TAP	
EL je dodržaný, ak v kalend. roku:	žiadna SPH neprekročí hodnotu 2*EL+I
	žiadna PDH neprekročí hodnotu EL+I
	najmenej 95 % zo všetkých SPH za kalend. mesiac neprekročí 1,2 EL+I

Meranie s TAP	
EL je dodržaný, ak v kalend. roku:	žiadna PDH neprekročí hodnotu EL