

Ročný protokol emisných hodnôt pre RP za :

2014

Palivo		Bez TAP				Spoluspaľovanie TAP				
ZL	SPH - 30 min	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
EL	[mg/Nm ³]	-	1300	400	50	-	800	50	30	30
I	[%EL]	10	20	20	30	10	20	20	30	30
N SPH > 2 EL+I		-	0	0	6	-	-	-	-	-
N PDH > EL+I		-	0	0	0	-	1	1	0	0
mesiace s % < 95% (%SPH < 1.2EL+I)					II,IV,					
N F PDH		3	3	3	1	6	6	6	5	6
% (F) z N _{stabil} (≤5%) / Účinnosť AMS		2,30 / 97,70	2,30 / 97,70	2,30 / 97,70	0,21 / 99,79	2,66 / 97,34	2,66 / 97,34	2,66 / 97,34	1,08 / 98,92	2,20 / 97,80
c - priem. hm. koncent. ZL ≤ EL [mg/m _{ns} ³]		28.9	843.3	3.6	2.8	26.6	522.9	3.7	2.6	3.1
množstvo ZL ≤ EL [kg]		1,822.9	53,151.7	224.7	150.5	24,406.4	478,881.6	3,357.4	2,385.2	2,881.6
Q Spalin ≤ EL [tis. m ³]		63,028	63,028	63,028	53,890	918,147	915,743	915,625	918,147	918,147
c - priem. hm. koncent. ZL > EL [mg/m _{ns} ³]		0.0	0.0	0.0	16.8	-	637.4	39.3	0.0	0.0
množstvo ZL > EL [kg]		0.0	0.0	0.0	153.9	-	1,532.3	99.1	0.0	0.0
Q Spalin > EL [tis. m ³]		0	0	0	9,139	-	2,404	2,522	0	0

Počet hodín za rok: 2741						Priemerné mesačné emisné hodnoty [mg/Nm ³]				Priemerné mesačné emisné hodnoty [mg/Nm ³]				
Stav:	Bez	Ust	Náb	ZmQ	Odst	Meranie bez TAP				Meranie so spoluspaľovaním TAP				
Deň	-	""	N	Q	Z	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
Jan-14	1488.	0/0	0.	0.	0.									
Feb-14	772.	10/411	0.	151.	0.	33.4	736.1	12.0	15.6	43.1	680.1	12.4	5.2	4.1
Mar-14	610.	11/647	0.	220.	0.	37.7	821.0	8.7	7.2	25.1	678.2	7.2	3.3	3.8
Apr-14	865.	63/355	0.	157.	0.	35.6	916.0	11.3	10.4	38.4	554.8	8.8	3.1	3.6
May-14	638.	43/505	0.	302.	0.	45.8	1,020.2	11.4	4.7	31.5	687.8	13.4	2.9	3.8
Jun-14	483.	83/576	0.	298.	0.	41.7	838.3	5.5	2.5	31.7	680.3	6.7	3.2	4.0
Jul-14	952.	61/310	0.	165.	0.	25.0	827.7	3.3	1.7	30.8	626.1	5.6	2.1	3.9
Aug-14	282.	85/716	0.	405.	0.	26.2	771.2	0.1	1.5	29.7	588.6	0.2	2.6	2.6
Sep-14	980.	7/350	0.	103.	0.	52.1	613.4	0.0	1.3	39.4	613.1	0.3	1.6	2.4
Oct-14	151.	102/799	0.	436.	0.	23.5	860.8	0.7	4.6	21.1	636.3	0.8	3.3	4.4
Nov-14	1324.	3/85	0.	28.	0.	22.9	749.3	0.0	1.1	21.6	589.4	0.0	2.0	3.9
Dec-14	1143.	10/250	0.	85.	0.	34.2	677.4	0.4	1.5	32.0	466.3	0.5	2.7	4.4
SUMA	9688.	478/5 004	0.	2350.	0.	34.4	802.9	4.9	4.7	31.3	618.3	5.1	2.9	3.7

Meranie bez TAP	
EL je dodržaný, ak v kalend. roku:	žiadna SPH neprekročí hodnotu 2*EL+I
	žiadna PDH neprekročí hodnotu EL+I
	najmenej 95 % zo všetkých SPH za kalend. mesiac neprekročí 1,2 EL+I

Meranie s TAP	
EL je dodržaný, ak v kalend. roku:	žiadna PDH neprekročí hodnotu EL